

# ADDENDUM NO. 3

May 3, 2010

TO

PROJECT MANUAL

FOR

WATER TREATMENT FACILITY REHABILITATION

FOR

CITY OF ST. CLOUD

ST. CLOUD, MINNESOTA

MARCH 2010

The following changes, additions, and deletions are hereby made a part of the Bidding Documents for the Water Treatment Facility Rehabilitation project as fully and completely as if the same were set forth therein. Acknowledge receipt of this addendum in the space provided on the Bid Form and also on the outside of the Bid envelope. **FAILURE TO DO SO MAY RESULT IN REJECTION OF BID.**

This addendum consists of two (2) pages and zero (0) attachments.

## SPECIFICATIONS

### SECTION 01400 – QUALITY CONTROL

1. Page 01400-2. **Delete** the last sentence of Paragraph 1.05.A and **replace** with the following: The independent testing firm will be paid at the expense of the Owner.

### SECTION 11260 – CHEMICAL FEED EQUIPMENT

1. Page 11260-7, Paragraph 2.04.A.1. **Delete** the text “double wall.”
2. Page 11260-8. **Delete** Paragraph 2.04.A.1.d in its entirety.

## DRAWINGS

### Drawing 8P01

1. Detail 2/8P01: **Delete** the words “DOUBLE WALLED” from the Fluoride Storage Tank Description.

2. Detail 2/8P01: **Delete** the Reverse Float Type Sight Gauge.


Drawing 8P02

1. **Add** the following text to the CONSTRUCTION NOTES:
  4. Contractor to route carrier pipe and tubing to chemical injection point. Fluoride chemical feed to remain continuous and not be interrupted during construction.

**ATTACHMENT LIST TO THIS ADDENDUM**

1. None.

I hereby certify that this plan, specification, or report was prepared by me or under my direct supervision, and that I am duly registered as a Professional Engineer under the laws of the State of Minnesota.



\_\_\_\_\_  
Jason Kosmatka, PE  
Registration Number 45841  
May 3, 2010

END OF ADDENDUM NO. 3